



INTERNATIONAL CONFERENCE ON
SAFETY OF LIFE AT SEA, 1974

Committee II

IMCO

DRAFT TEXT OF THE INTERNATIONAL CONVENTION
FOR THE SAFETY OF LIFE AT SEA, 1974

Text of Chapter II-2 as
agreed by the Committee

Addendum

38. Regulation 3

Insert the footnote to paragraph (a) as follows:

"Reference is made to Recommendation on Test Method for
Qualifying Marine Construction Materials as Non-Combustible,
adopted by the Organization by Resolution A.270(VIII)."

39. Insert the footnote to paragraphs (b) and (c) as follows:

"Reference is made to Recommendation for Fire Test Procedures
for "A" and "B" Class Divisions, adopted by the Organization by
Resolutions A.163(ES.IV) and A.215(VII)."

40. Regulations 27, 40 and 57

Insert the footnote to paragraph (e) of Regulation 27, to sub-
paragraph (a)(iii) of Regulation 40 and to sub-paragraph (b)(v)
of Regulation 57 as follows:

"Reference is made to Guidelines on the Evaluation of Fire
Hazard Properties of Materials, adopted by the Organization by
Resolution A.166(ES.IV)."

41. Regulations 27, 41, 51 and 57

Insert the footnote to paragraph (h) of Regulation 27, to the
heading of Regulation 41, to paragraph (c) of Regulation 51 and
to sub-paragraph (a)(viii) of Regulation 57 as follows:

"Reference is made to Improved Provisional Guidelines on Test Procedures for Primary Deck Coverings, adopted by the Organization by Resolution A.214(VII)."

42. Regulation 30

Insert the footnote to paragraph (c) as follows:

"Reference is made to Recommendation on Fixed Fire Extinguishing Systems for Special Category Spaces, adopted by the Organization by Resolution A.123(V)."

43. Parts A and D

Insert the footnote to headings of Part A and Part D as follows:

"Reference is made to Recommendation on Safety Measures for Periodically Unattended Machinery Spaces of Cargo Ships Additional to those normally Considered Necessary for an Attended Machinery Space, adopted by the Organization by Resolution A.211(VII)."

44. Regulation 56

Replace sub-paragraph (f)(i) by the following:

"(i) No doors shall be permitted in such boundaries, except that doors to those spaces not having access to accommodation and service spaces, such as cargo control stations, provision rooms, and store rooms may be permitted by the Administration. Where such doors are fitted, the boundaries of the space shall be insulated to "A-60" Class. Bolted plates for removal of machinery may be fitted in such boundaries."

45. Regulation 47

In sub-paragraph (f)(i) replace the words "a fixed fire extinguishing gas system" by "a fixed gas fire-extinguishing system."

46. Regulation 52

In sub-paragraph (f)(i) replace the words "a fixed fire extinguishing system" by "a fixed gas fire-extinguishing system."
