

**International Code  
for Fire Safety Systems  
(FSS Code)**

2015 Edition

**Corrigenda**  
February 2017

*In the footnote on pages 66, 139 and 216 of the FSS Code, change “(m·s)<sup>0.5</sup>” to “(m/s)<sup>0.5</sup>” as follows:*

“

---

\* If the value of  $C$  is determined to be less than  $0.5 \text{ (m/s)}^{0.5}$ , a  $C$  of  $0.25 \text{ (m/s)}^{0.5}$  should be assumed for calculating RTI value.”